

**Top Ten Deficiencies National and Virginia
Life Safety Code
Long Term Care**

RANK	NATIONAL 2011	VIRGINIA 2011	VIRGINIA 2010	VIRGINIA 2009
#1	K0147. Electrical wiring and equipment	K0147. Electrical wiring and equipment	K0147. Electrical wiring and equipment	K0062. Sprinkler system maintenance
#2	K0062. Sprinkler system maintenance	K0062. Sprinkler system maintenance	K0062. Sprinkler system maintenance	K0147. Electrical wiring and equipment
#3	K0029. Hazardous areas - separation	K0018. Corridor doors	K0018. Corridor doors	K0018. Corridor doors
#4	K0018. Corridor doors	K0038. Exit Access	K0029. Hazardous areas - separation	K0025. Smoke partition construction
#5	K0038. Exit Access	K0029. Hazardous areas - separation	K0038. Exit Access	K0038. Exit Access
#6	K0025. Smoke partition construction	K0027 Doors in Smoke Partitions	K0025. Smoke partition construction	K0029. Hazardous areas - separation
#7	K0144. Generator inspected/tested	K0025. Smoke partition construction	K0027 Doors in Smoke Partitions	K0027. Doors in smoke partitions.
#8	K0050. Fire drills	K0052. Testing of the fire alarm.	K0056. Automatic Sprinkler system	K0144. Generator inspected/tested
#9	K0056. Automatic Sprinkler system	K0056. Automatic Sprinkler system	K0052. Testing of the fire alarm.	K0052. Testing of the fire alarm.
#10	K0012 Construction Type	K0069 Cooking Equipment	K0130 Other	K0056. Automatic Sprinkler system

3/5/2012